



P-20

LUBRICANT FOR PIPE SYSTEMS WITH RUBBER SLEEVE CONNECTIONS



PRODUCT DESCRIPTION

Lubricant for pipe systems with rubber sleeve connections.



FIELD OF APPLICATION

For assembling pipes, sleeves and fittings with rubber sleeve (sliding socket) connections in pressurised and drain systems. Approved for drinking water systems based on toxicological and bacteriological properties. Suitable for all diameters. Suitable for PVC-U, ABS, PE, PP, GRP, concrete and coated cast iron.

PROPERTIES

- Re-adjustable
- Thixotropic
- Water rinsable

CERTIFICATES & STANDARDS

Certificates	
	KIWA: Lubricants for fittings with a rubber sleeve connection. Approved for drinking water. Certificate K5165 based on BRL K535.
	WRAS: Approved for drinking water. WRAS certificate (BS 6920).

PREPARATION

Working Conditions: Do not use in temperatures $\leq +0^{\circ}\text{C}$.

APPLICATION

Ø	32	40	50	75	90	110	160	250
#	900	600	400	200	135	90	45	20

Directions for use:

1. Cut pipes square, remove burrs and chamfer. 2. Remove dirt and moisture. 3. Apply slipping agent to pipe end and rubber sleeve. 4. Join parts immediately by sliding the tube into the sliding socket until the stopper. Joint is adjustable for a few hours. Properly close the container immediately after use.

Stains/residue: Remove residues with water.

TECHNICAL SPECIFICATIONS

Chemical base:	Fatty acid
Colour:	White
Density approx.:	0,9 g/cm ³
Viscosity:	Pasty

STORAGE CONDITIONS

Stored in unopened packaging between $+5^{\circ}\text{C}$ and $+25^{\circ}\text{C}$. Best Before Date (MM/YY): see packaging. Close packaging properly after use and store in a dry, cool, and frost-free location.

Our advice is based on extensive research and practical experience. However, in view of the large variety of materials and the conditions under which our products are applied, we assume no responsibility for the results obtained and/or any damage caused by the use of the product. Nevertheless, our Service Department is always at your disposal for any advice needed.